



12423 NE Whitaker Way
Portland, OR 97230
503-254-1794



Report Number: 22-014463/D002.R00
Report Date: 12/05/2022
ORELAP#: OR100028
Purchase Order:
Project Name: Outbuildings
Project No: Banks School District

Cover Letter

Indy Safety
5010 NE Roselawn ST
Portland Oregon 97218
United States of America (USA)

Dear Elessar Connolly-Fairchild,

Enclosed please find Columbia Laboratories analytical report for samples received as order number 22-014463 on 11/18/2022 at 15:34. Should you have any questions about this report or any other matter, please do not hesitate to contact us. We are here to help you.

Thank you for allowing Columbia Laboratories to be of service to you, we appreciate your business.

Sincerely,

Derrick Tanner
General Manager



12423 NE Whitaker Way
 Portland, OR 97230
 503-254-1794



Report Number: 22-014463/D002.R00
Report Date: 12/05/2022
ORELAP#: OR100028
Purchase Order:
Project Name: Outbuildings
Project No: Banks School District

Sample Results

Sample: 22400303-001 BF 22A Collected: 11/18/22 09:07 Temp: 16.6 °C Matrix:
 Lab ID: 22-014463-0001 Received: 11/18/22 15:34 Evidence of Cooling: N Drinking Water

Method: EPA 200.8 in mg/l

Analyte	Result	Limit	Units	LOQ	Dil.	Batch	Start/Extract	Analyzed	Notes
Lead [§]	1.1000	15.000	µg/L	0.2000	1.00	2210306		11/30/22 16:40	

Sample Results

Sample: 22400303-002 BF 22A Collected: 11/18/22 09:08 Temp: 16.6 °C Matrix:
 Lab ID: 22-014463-0002 Received: 11/18/22 15:34 Evidence of Cooling: N Drinking Water

Method: EPA 200.8 in mg/l

Analyte	Result	Limit	Units	LOQ	Dil.	Batch	Start/Extract	Analyzed	Notes
Lead [§]	2.0500	15.000	µg/L	0.2000	1.00	2210306		11/30/22 16:41	

Sample Results

Sample: 22400303-003 BF 22A Collected: 11/18/22 09:09 Temp: 16.6 °C Matrix:
 Lab ID: 22-014463-0003 Received: 11/18/22 15:34 Evidence of Cooling: N Drinking Water

Method: EPA 200.8 in mg/l

Analyte	Result	Limit	Units	LOQ	Dil.	Batch	Start/Extract	Analyzed	Notes
Lead [§]	2.8700	15.000	µg/L	0.2000	1.00	2210306		11/30/22 16:43	

Sample Results

Sample: 22400303-004 BF 22A Collected: 11/18/22 09:10 Temp: 16.6 °C Matrix:
 Lab ID: 22-014463-0004 Received: 11/18/22 15:34 Evidence of Cooling: N Drinking Water

Method: EPA 200.8 in mg/l

Analyte	Result	Limit	Units	LOQ	Dil.	Batch	Start/Extract	Analyzed	Notes
Lead [§]	4.7600	15.000	µg/L	0.2000	1.00	2210306		11/30/22 16:44	

Sample Results

Sample: 22400303-005 BF 22A Collected: 11/18/22 09:11 Temp: 16.6 °C Matrix:
 Lab ID: 22-014463-0005 Received: 11/18/22 15:34 Evidence of Cooling: N Drinking Water

Method: EPA 200.8 in mg/l

Analyte	Result	Limit	Units	LOQ	Dil.	Batch	Start/Extract	Analyzed	Notes
Lead [§]	1.0700	15.000	µg/L	0.2000	1.00	2210306		11/30/22 16:46	



12423 NE Whitaker Way
 Portland, OR 97230
 503-254-1794



Report Number: 22-014463/D002.R00
Report Date: 12/05/2022
ORELAP#: OR100028
Purchase Order:
Project Name: Outbuildings
Project No: Banks School District

Sample Results

Sample: 22400303-006 BF 22A Collected: 11/18/22 09:12 Temp: 16.6 °C Matrix:
 Lab ID: 22-014463-0006 Received: 11/18/22 15:34 Evidence of Cooling: N Drinking Water

Method: EPA 200.8 in mg/l									
Analyte	Result	Limit	Units	LOQ	Dil.	Batch	Start/Extract	Analyzed	Notes
Lead*	1.5000	15.000	µg/L	0.2000	1.00	2210306		11/30/22 16:47	

Sample Results

Sample: 22400309-001 KF 22A Collected: 11/18/22 09:17 Temp: 16.6 °C Matrix:
 Lab ID: 22-014463-0007 Received: 11/18/22 15:34 Evidence of Cooling: N Drinking Water

Method: EPA 200.8 in mg/l									
Analyte	Result	Limit	Units	LOQ	Dil.	Batch	Start/Extract	Analyzed	Notes
Lead*	2.1000	15.000	µg/L	0.2000	1.00	2210306		11/30/22 16:48	

Sample Results

Sample: 22400309-002 KF 22A Collected: 11/18/22 09:18 Temp: 16.6 °C Matrix:
 Lab ID: 22-014463-0008 Received: 11/18/22 15:34 Evidence of Cooling: N Drinking Water

Method: EPA 200.8 in mg/l									
Analyte	Result	Limit	Units	LOQ	Dil.	Batch	Start/Extract	Analyzed	Notes
Lead*	2.2700	15.000	µg/L	0.2000	1.00	2210306		11/30/22 16:50	

Units of Measure

µg/L = Micrograms per liter = parts per billion (ppb)

Abbreviations

LOQ Limit of quantification

* = TNI accredited analyte.



12423 NE Whitaker Way
 Portland, OR 97230
 503-254-1794



Report Number: 22-014463/D002.R00
 Report Date: 12/05/2022
 ORELAP#: OR100028
 Purchase Order:
 Project Name: Outbuildings
 Project No: Banks School District

INDYSAFE 22-014463



Indy Safety



Environmental Chain of Custody Record

Revision: 4.00 Document Control: CF001
 Revised: 01/18/2021 Effective: 03/16/2021

Please inform us if you know or suspect that any part of your sample may contain hazardous materials or chemicals.

Company: <u>INDY SAFETY</u>	Analysis Requested	PO Number: _____
Contact: <u>ELESSAR CONNORLY FARREHOLD</u>		Project Number: <u>BANKS SCHOOL DISTRICT</u>
Address: <u>5010 NE ROSSETT</u>		Project Name: <u>OUTBUILDINGS</u>
<u>PORTLAND, OR 97218</u>		Custom Reporting: _____
Email: <u>ELESSAR@INDYSAFETY.COM</u>		<input type="checkbox"/> Report to State: _____
Phone: <u>(503) 481-2193</u> Fax: _____	Turn-around time: <input checked="" type="checkbox"/> Standard <input type="checkbox"/> Other, Due: _____	Rush: <input type="checkbox"/> 4 day <input type="checkbox"/> 3 day <input type="checkbox"/> 2 day <input type="checkbox"/> Next day
Billing (if different): _____	Preservative code: Verification of type used †	*Ask for availability. Samples received after 3pm are considered as received the following business day.
		Sampled by: <u>ELESSAR CONNORLY-FARREHOLD</u>

Lab ID	Field / Sample ID	Date/Time	Matrix ??	Comments
22400	303-001 BF 22A	11/18/22 9:07	DW	Lot # 8417 1 Sample name - 22400 309-002 KF 22A Per bottles JSF 11/28
22400	303-002 BF 22A	9:08		
22400	303-003 BF 22A	9:09		
22400	303-004 BF 22A	9:10		
22400	303-005 BF 22A	9:11		
22400	303-006 BF 22A	9:12		
22400	309-001 KF 22A	9:17		
22400	309-001 KF 22A	9:18		
22400	303-001			
22400	303-001			

Relinquished By: <u>E Lessar-Farredo</u>	Date: <u>11/18/22</u> Time: <u>3p</u>	Received By: <u>JMV</u>	Date: <u>11/18/22</u> Time: <u>15:34</u>	Lab Use Only:
				<input type="checkbox"/> Shipped Via: _____ or <input checked="" type="checkbox"/> Client drop off
				Evidence of cooling: <input type="checkbox"/> yes <input checked="" type="checkbox"/> No - Temp (°C): <u>16.6</u>
				If temp out, proceed?: <input type="checkbox"/> yes <input type="checkbox"/> No _____
				<input type="checkbox"/> Cash <input type="checkbox"/> Check <input type="checkbox"/> CC <input type="checkbox"/> Net: _____

Samples submitted to CL with testing requirements constitute an agreement for services in accordance with the current terms of service associated with this COC. By signing "Relinquished by" you are agreeing to these terms.

12423 NE Whitaker Way
 Portland, OR 97230

P: (503) 254-1794 | Fax: (503) 254-1452
 info@columbiaboratories.com

Page 1 of 1
 www.columbiaboratories.com

Test results relate only to the parameters tested and to the samples as received by the laboratory. Test results meet all requirements of NELAP and the Columbia Laboratories quality assurance plan unless otherwise noted. This report shall not be reproduced, except in full, without the written consent of this laboratory. Samples will be retained for a maximum of 30 days from the receipt date unless prior arrangements have been made.



12423 NE Whitaker Way
Portland, OR 97230
503-254-1794



Report Number: 22-014463/D002.R00
Report Date: 12/05/2022
ORELAP#: OR100028
Purchase Order:
Project Name: Outbuildings
Project No: Banks School District

Case Narrative

No Case Narrative notes to report.